

臺北榮民總醫院藥學部

臨床試驗藥局細胞毒性藥品冷藏/室溫溫度管制表 109年 03月

	六號冰箱		室溫	
序號	1436-0086		1118-0011	
備用	0436-049		0742-0169	
範圍	2~8°C		15~25°C	
日期	Min	Max	Min	Max
2020/3/1	4.7	5.1	19.2	19.5
2020/3/2	4.7	5.4	18.9	19.3
2020/3/3	4.7	4.9	19	19.6
2020/3/4	4.7	4.9	19.2	19.6
2020/3/5	4.5	5.2	18.8	19.2
2020/3/6	4.4	5.1	18.8	19.2
2020/3/7	4.4	4.9	18.6	19.2
2020/3/8	4.4	4.9	19.1	19.4
2020/3/9	4.3	4.9	19.2	19.8
2020/3/10	4.4	5.1	19	19.8
2020/3/11	4.5	5	18.6	19.1
2020/3/12	4.4	5.1	19.1	19.7
2020/3/13	4.4	4.9	19.2	19.9
2020/3/14	4.4	5	18.6	19.4
2020/3/15	4.5	5	18.2	18.7
2020/3/16	4.3	4.9	18.6	19.1
2020/3/17	4.4	4.9	18.8	19.3
2020/3/18	4.4	4.9	18.9	19.6
2020/3/19	4.4	4.9	19.2	19.8
2020/3/20	4.4	4.8	19.4	19.9
2020/3/21	4.4	4.8	19.4	19.6
2020/3/22	4.4	4.8	19.4	19.7
2020/3/23	4.3	4.8	19.4	19.9
2020/3/24	4.4	4.8	19.4	20.1
2020/3/25	4.4	4.8	19.9	20.3
2020/3/26	4.3	4.9	19.8	20.4
2020/3/27	4.4	5	20.1	20.3
2020/3/28	4.3	4.8	19.7	20.2
2020/3/29	4.4	4.8	19.4	19.8
2020/3/30	4.1	4.9	19.7	20.3
2020/3/31	4.2	6.5	19.6	20.9

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 1090345
藥學部 西雅如 1090401