

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 109年02月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max
2020/2/1	4	4.7	3.9	4.5	19.9	20.2
2020/2/2	4	4.7	3.9	4.5	20.2	20.6
2020/2/3	3.9	4.6	3.8	4.4	20.7	21.1
2020/2/4	3.9	4.8	3.8	5.1	21.1	21.6
2020/2/5	3.8	4.7	3.8	4.9	21.1	21.4
2020/2/6	3.8	4.5	3.9	5.2	21.1	21.7
2020/2/7	3.8	4.5	4	4.7	21.1	21.4
2020/2/8	3.8	4.5	4	4.7	20.6	21.1
2020/2/9	3.8	4.5	4	4.7	20.6	20.6
2020/2/10	3.8	4.6	4	4.8	20.4	20.9
2020/2/11	3.9	5.7	3.9	4.8	20.9	21.4
2020/2/12	4.3	5.2	3.9	5.3	21.3	21.9
2020/2/13	4.3	5.3	3.8	4.8	21.7	21.8
2020/2/14	4.3	5.2	4.2	4.8	21.5	21.7
2020/2/15	4.4	5.2	4.2	4.8	21.3	21.5
2020/2/16	4.4	5.2	4.1	4.8	20.6	21.3
2020/2/17	4.3	5.3	4.1	4.9	19.9	20.6
2020/2/18	4.3	5.2	3.9	4.9	19.7	19.9
2020/2/19	4.3	5.2	3.7	4.7	19.7	20.1
2020/2/20	4.3	5.1	3.8	4.7	20.1	20.6
2020/2/21	4.2	5.1	3.6	4.8	20.5	20.8
2020/2/22	4.2	5	3.7	4.6	20.7	20.8
2020/2/23	4.2	5	3.7	4.6	20.3	20.7
2020/2/24	4.2	5.5	3.7	4.6	20.1	20.3
2020/2/25	4.2	5.1	3.8	4.5	20.2	20.6
2020/2/26	4.2	5.3	3.9	4.9	20.4	20.7
2020/2/27	4.4	5.5	3.8	4.6	20.5	20.7
2020/2/28	4.8	5.4	3.8	4.3	20.4	20.7
2020/2/29	4.8	5.4	3.8	4.4	20.3	20.4

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥
師(三)級藥師 10903020439
藥學部 溫雅如
師(三)級藥師 10903020636

溫度均在正常範圍內