

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 108年11月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max
2019/11/1	5	5.6	4.5	5.8	21.5	21.8
2019/11/2	4.9	5.6	4.7	5.1	21.4	21.7
2019/11/3	5	5.6	4.7	5.1	21.4	21.6
2019/11/4	4.3	5.6	4.7	5.9	21.3	21.4
2019/11/5	4.4	5.1	5.3	5.9	21.2	21.6
2019/11/6	4.4	5	4.9	5.7	21.3	21.5
2019/11/7	4.3	5.1	5.1	5.7	21.2	21.5
2019/11/8	4.2	5	4.8	5.4	21.2	21.4
2019/11/9	4.3	4.9	4.9	5.3	20.9	21.3
2019/11/10	4.3	4.9	4.9	5.3	20.6	20.9
2019/11/11	4.3	5.7	4.9	5.6	20.4	20.7
2019/11/12	5.1	5.6	5.1	5.7	20.7	21.1
2019/11/13	5.1	6.1	5.1	5.7	21.1	21.4
2019/11/14	5.3	6	4.6	5.9	21.3	21.8
2019/11/15	4.8	5.9	4.6	5.8	21.4	21.7
2019/11/16	4.7	5.5	5.3	5.8	21.4	21.6
2019/11/17	4.9	5.5	5.3	5.7	21.2	21.4
2019/11/18	4.6	5.6	5.1	6	21.1	21.5
2019/11/19	4.6	5.5	5.4	6	21.3	21.4
2019/11/20	4.6	5.4	5.3	6.1	21.3	21.4
2019/11/21	4.7	5.6	4.2	6.1	21.3	21.7
2019/11/22	4.7	6.2	4.2	4.9	21.4	21.7
2019/11/23	4.7	5.7	4.5	5.1	21.4	21.7
2019/11/24	4.7	5.3	4.5	4.9	21.2	21.6
2019/11/25	4.3	5.4	4.2	5.2	21.1	21.4
2019/11/26	4.3	5.3	4.2	4.9	21.2	21.5
2019/11/27	4.5	5.2	4.2	4.8	21.3	21.7
2019/11/28	4.4	5.2	4.3	5.1	21.3	21.6
2019/11/29	4.4	5.1	4.2	5.4	21.1	21.4
2019/11/30	4.4	5.2	4.1	4.8	21.1	21.3

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 108
師(三)級藥師 202 藥學部 溫雅如 108
師(三)級藥師 202

溫度均在正常範圍內