

臺北榮民總醫院藥學部

臨床試驗藥局細胞毒性藥品冷藏/室溫溫度管制表 108年05月

	六號冰箱		室溫	
序號	1436-0086		1118-0011	
備用	0436-049		0742-0169	
範圍	2~8℃		15~25℃	
日期	Min	Max	Min	Max
2019/5/1	3.9	4.6	19.9	20.7
2019/5/2	3.9	4.2	19.9	20.4
2019/5/3	3.8	5.2	20.2	20.8
2019/5/4	3.8	4.2	19.9	20.2
2019/5/5	3.8	4.2	19.8	20.2
2019/5/6	3.8	4.2	19.6	20.4
2019/5/7	3.8	4.1	19.4	19.9
2019/5/8	3.8	4.2	19.3	20.1
2019/5/9	3.7	4.2	19.4	19.9
2019/5/10	3.8	4.2	19.4	19.7
2019/5/11	3.7	4.2	18.9	19.7
2019/5/12	3.7	4.1	18.8	19.4
2019/5/13	3.7	4.1	18.6	19.2
2019/5/14	3.7	4.3	19	19.5
2019/5/15	4.1	4.4	19.1	19.4
2019/5/16	4.1	4.3	19.2	20.4
2019/5/17	4.1	4.4	19.3	19.7
2019/5/18	4.2	4.3	19	19.5
2019/5/19	4.2	4.3	18.9	19.2
2019/5/20	4.2	4.4	18.9	19.9
2019/5/21	4.1	4.3	19.7	20.1
2019/5/22	4	4.3	19.9	20.3
2019/5/23	4	4.3	19.5	20
2019/5/24	4.1	4.3	19.4	19.7
2019/5/25	4.2	4.3	19.2	19.7
2019/5/26	4.2	4.3	19	19.6
2019/5/27	4.2	4.6	18.9	19.4
2019/5/28	4.2	4.5	19.2	19.7
2019/5/29	4.2	4.4	19.6	20.3
2019/5/30	4.1	4.4	19.4	20.1
2019/5/31	4.1	4.5	19.3	19.6

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部溫雅如 108
 藥師(三)級藥師 邱保祥 108
 藥學部 邱保祥 108
 藥師(三)級藥師 邱保祥 108