

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 108年01月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8℃		2~8℃		15~25℃	
日期	Min	Max	Min	Max	Min	Max
2019/1/1	5.5	5.8	4.1	4.7	20.9	21.1
2019/1/2	5.3	5.8	3.5	4.6	20.9	21.3
2019/1/3	5.3	6.1	3.6	5.4	21.1	21.7
2019/1/4	5.3	6.1	4.7	5.3	21.4	22.1
2019/1/5	5.3	5.7	4.6	5.2	21.3	21.7
2019/1/6	5.3	5.7	4.6	5.2	21.1	21.3
2019/1/7	5.3	5.8	4.6	5.2	20.9	21.2
2019/1/8	5.3	6.1	3.8	5.2	20.5	21.3
2019/1/9	5.4	6.3	3.7	4.9	20.9	21.7
2019/1/10	5.4	6.1	4	4.7	21.1	21.9
2019/1/11	5.3	5.8	4	4.9	21.2	21.8
2019/1/12	5.3	5.7	4.4	5	21.2	21.7
2019/1/13	5.2	5.7	4.4	4.9	20.7	21.2
2019/1/14	5.2	5.9	3.8	4.9	20.6	21.6
2019/1/15	5.2	6	3.9	4.6	21.1	22
2019/1/16	5.2	5.9	3.9	4.7	21.3	21.8
2019/1/17	5.1	5.7	4	4.7	21.1	21.7
2019/1/18	4.9	5.6	4	4.7	20.8	21.3
2019/1/19	4.9	5.5	4	4.7	20.9	21.3
2019/1/20	5.1	5.7	4	4.7	21.2	23.3
2019/1/21	5.1	5.9	4	4.7	22.1	23.1
2019/1/22	4.8	5.9	4	4.8	21.4	22.1
2019/1/23	4.8	5.4	4	4.8	20.9	21.7
2019/1/24	4.8	5.5	4.1	4.9	20.9	21.7
2019/1/25	4.7	5.4	4.3	5.2	21.2	21.9
2019/1/26	4.7	5.3	4.3	4.9	20.7	21.7
2019/1/27	4.7	5.3	4.3	4.9	20.3	20.7
2019/1/28	4.7	5.7	4.3	5.4	20.1	20.9
2019/1/29	4.7	5.6	4.3	5.2	20.6	21.6
2019/1/30	4.7	5.8	4.3	5.3	20.9	21.7
2019/1/31	5.2	6.1	4.6	5.3	21.1	21.8

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 溫度均在正常範圍內

藥學部 邱保祥 108
師(三)級藥師 201

藥學部 溫雅如 108
師(三)級藥師 201