

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 109 年 10 月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max
2020/10/1	3.6	4.6	5.1	5.7	21.3	21.6
2020/10/2	3.6	4.6	5.1	5.7	21.1	21.3
2020/10/3	3.6	4.6	5.1	5.7	21.1	21.1
2020/10/4	3.6	4.7	5.1	5.7	20.8	21.1
2020/10/5	3.7	4.7	4.9	5.9	20.8	21.3
2020/10/6	3.7	4.7	4.8	6.1	21.1	21.6
2020/10/7	3.7	5.6	4.7	5.7	21.3	21.6
2020/10/8	3.6	4.7	4.7	5.5	21.3	21.7
2020/10/9	3.7	4.5	4.7	5.4	21.3	21.7
2020/10/10	3.7	4.5	4.7	5.4	21.1	21.3
2020/10/11	3.7	4.6	4.7	5.5	20.9	21.1
2020/10/12	3.3	5.1	4.7	6.1	20.7	21.1
2020/10/13	3.3	4.7	4.8	5.6	21.1	21.3
2020/10/14	3.4	4.6	4.8	5.6	21.1	21.4
2020/10/15	3.6	4.6	4.8	5.7	21.3	21.6
2020/10/16	3.7	5.7	4.9	5.7	21.3	21.7
2020/10/17	3.7	4.7	4.9	5.7	21.3	21.7
2020/10/18	3.7	4.7	4.9	5.7	21	21.3
2020/10/19	3.6	4.7	4.9	5.7	20.9	21.1
2020/10/20	3.6	4.9	4.9	5.9	21.1	21.3
2020/10/21	3.4	4.7	5	6.2	21.1	21.4
2020/10/22	3.4	4.4	5	6.1	21.3	21.5
2020/10/23	3.5	5.8	4.9	6.1	21.3	21.4
2020/10/24	3.6	4.4	5.1	5.9	21.1	21.3
2020/10/25	3.6	4.4	5.1	5.9	20.7	21.1
2020/10/26	3.5	4.6	4.9	6.1	20.6	20.9
2020/10/27	3.5	4.6	4.9	5.9	20.8	21.1
2020/10/28	3.6	4.5	4.9	6.1	20.9	21.3
2020/10/29	3.6	5.6	4.9	6.1	21.1	21.4
2020/10/30	3.9	4.8	4.6	6.4	21.2	21.3
2020/10/31	3.8	4.5	4.7	5.6	21.1	21.3

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師:

溫度均在正常範圍內

藥學部 邱保祥 109
師(三)級藥師 1102

藥學部 溫雅如 109
師(三)級藥師 1102