

臺北榮民總醫院藥學部

臨床試驗藥局細胞毒性藥品冷藏/室溫溫度管制表 110 年 03 月

	六號冰箱		室溫	
序號	1436-0086		1118-0011	
備用	0436-049		0742-0169	
範圍	2~8°C		15~25°C	
日期	Min	Max	Min	Max
2021/3/1	4.3	4.6	19	19.4
2021/3/2	4.3	5.2	18.8	19.1
2021/3/3	4.4	5	18.6	19.3
2021/3/4	4.6	5.1	18.8	19.7
2021/3/5	4.7	5.3	18.6	19.6
2021/3/6	5.1	5.3	18.8	19.5
2021/3/7	5.1	5.2	19.3	19.5
2021/3/8	4.9	5.4	19.2	19.7
2021/3/9	4.9	5.2	18.8	19.7
2021/3/10	4.9	5.2	18.9	19.6
2021/3/11	4.9	5.2	19.1	19.7
2021/3/12	4.8	5.6	18.8	19.7
2021/3/13	4.7	5	19.2	19.5
2021/3/14	4.7	5	19	19.7
2021/3/15	4.7	5.2	19.3	19.7
2021/3/16	4.7	5.3	19.2	19.6
2021/3/17	4.8	5.5	19.3	20.1
2021/3/18	4.8	5.2	19.5	20.2
2021/3/19	4.9	5.2	19.4	20.1
2021/3/20	4.9	5.2	19.6	19.9
2021/3/21	4.9	5.2	19.1	19.7
2021/3/22	4.9	5.3	18.6	19.1
2021/3/23	4.9	5.2	18.7	19.5
2021/3/24	4.9	5.3	18.8	19.7
2021/3/25	4.9	5.3	18.4	19.4
2021/3/26	4.9	5.3	19	19.5
2021/3/27	5.1	5.3	18.8	19.4
2021/3/28	4.9	5.3	19	19.7
2021/3/29	4.9	5.3	18.9	19.7
2021/3/30	4.9	5.2	19.1	19.7
2021/3/31	4.9	5.2	19.2	19.9

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 110 0401
藥學部 溫雅如 110 0406

溫度均在正常範圍內