

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 112 年 03 月

	零號冰箱		四號冰箱		五號冰箱		八號冰箱		室溫2	
序號	2052-0128		1611-0062		1715-0118		2123-0024		1715-0116	
備用	2052-0129		1611-0052		1715-0119		2123-0025		1715-0117	
範圍	2~8°C		2~8°C		2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2023/3/1	5.9	6.2	4.2	5.5	4.4	6.1	5.9	6.1	20.6	21.3
2023/3/2	5.9	6.2	4.2	5.2	4.6	5.8	5.7	6.1	20.9	21.3
2023/3/3	5.9	6.3	4.1	4.9	4.7	5.7	5.1	6	20.9	21.2
2023/3/4	5.9	6.2	4.1	4.8	4.7	5.7	5.1	5.7	20.7	21.1
2023/3/5	5.9	6.2	4.1	4.8	4.7	5.7	5.1	5.7	20.5	20.9
2023/3/6	5.9	6.2	4	4.8	4.7	5.8	5.1	5.7	20.3	20.7
2023/3/7	5.9	6.2	4	4.8	4.3	5.7	5.1	5.8	20.6	21.3
2023/3/8	5.9	6.2	4	4.9	4.3	7.4	5.1	5.7	21.1	21.7
2023/3/9	5.9	6.3	4.1	5.1	4.3	5.5	5.1	5.7	21.4	21.8
2023/3/10	5.9	6.4	4.1	5.4	4.2	5.6	5.1	5.7	21.7	22.6
2023/3/11	6.1	6.4	4.2	5.1	4.3	5.6	5.1	5.7	21.9	22
2023/3/12	6.1	6.4	4.2	5.1	4.3	5.6	5.1	5.7	21.7	21.9
2023/3/13	6.1	6.4	4.2	5.1	4.3	5.6	5	5.7	21.5	21.8
2023/3/14	6.1	6.4	4.2	5.2	4.3	5.6	5	5.7	21.5	22
2023/3/15	6.1	6.4	4.1	5.1	4.3	5.5	4.9	5.7	21.7	22.1
2023/3/16	6.1	6.4	4.1	5.3	4.3	5.4	4.9	5.8	21.9	22.4
2023/3/17	6.1	6.4	4.1	5.1	4	5.4	4.9	5.7	22.2	22.6
2023/3/18	6.1	6.4	4.2	5.1	4.1	5.2	4.9	5.6	22.1	22.5
2023/3/19	6.1	6.3	4.2	5.1	4.1	5.3	4.9	5.6	21.9	22.1
2023/3/20	6.1	6.4	4.2	5.1	3.9	5.3	4.9	5.6	21.7	22
2023/3/21	6.1	6.3	4.2	5.1	3.8	5.2	4.8	5.6	21.9	22.2
2023/3/22	6	6.4	4.2	5.1	4	5.1	4.8	6.1	22.1	22.6
2023/3/23	6.1	6.4	4.2	5.1	3.9	5.7	4.7	5.3	22.3	22.8
2023/3/24	6.1	6.5	4.2	5.4	3.9	4.9	4.9	5.5	22.4	22.9
2023/3/25	6.2	6.4	4.4	5.1	3.9	4.9	5.1	5.6	22.4	22.8
2023/3/26	6.1	6.4	4.3	5.1	3.9	4.9	5.1	5.5	22.2	22.6
2023/3/27	6.1	6.4	4.3	5.1	3.9	5.1	5.1	5.6	21.9	22.2
2023/3/28	6.1	6.4	4.3	5.3	4	5.2	5	5.6	21.9	22.3
2023/3/29	6.1	6.4	4.3	5.2	4	5.9	4.7	5.5	22.1	22.4
2023/3/30	6	6.4	4.3	5.2	3.9	6	4.7	5.4	22.2	22.4
2023/3/31	5.4	6.3	4.3	5.2	3.9	4.9	4.7	5.5	22.2	22.5

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師 藥學部 邱保祥 112 406
藥學部 邱子芹 112 406

總藥師: 藥學部 廖志峰 112 407

業管主管: 藥學部 何沁沁 112 407