

臺北榮民總醫院藥學部

臨床試驗藥局細胞毒性藥品冷藏/室溫溫度管制表 107年11月

	六號冰箱		室溫	
序號	1436-0086		1118-0011	
備用	0436-049		0742-0169	
範圍	2~8°C		15~25°C	
日期	Min	Max	Min	Max
2018/11/1	3.8	5.6	20.4	21.1
2018/11/2	3.8	4.1	20.3	21.3
2018/11/3	3.7	4.1	20.7	21.2
2018/11/4	3.8	4.1	20.4	20.9
2018/11/5	3.7	4.2	20.3	20.8
2018/11/6	3.8	4.3	20.3	20.8
2018/11/7	3.9	4.2	20.1	20.8
2018/11/8	3.9	4.3	20.2	21.1
2018/11/9	3.9	4.2	20.6	21.2
2018/11/10	3.9	4.2	20.6	21.2
2018/11/11	3.9	4.2	20.4	20.8
2018/11/12	3.9	4.2	20.3	20.9
2018/11/13	3.9	4.1	20.4	21
2018/11/14	3.7	4.2	20.8	21.4
2018/11/15	3.7	4	21.1	21.7
2018/11/16	3.7	4.2	21.1	21.7
2018/11/17	3.7	4	21.7	22.2
2018/11/18	3.7	3.9	21.3	22
2018/11/19	3.7	4	21.1	21.8
2018/11/20	3.7	4.1	20.9	21.6
2018/11/21	3.7	4.2	20.8	21.7
2018/11/22	3.7	4.2	20.7	21.3
2018/11/23	3.7	4	20.4	20.9
2018/11/24	3.7	4	20.4	20.7
2018/11/25	3.8	4	19.9	20.4
2018/11/26	3.7	4.1	20.2	20.9
2018/11/27	3.7	4.1	20.3	21.1
2018/11/28	3.8	4.3	20.5	21.3
2018/11/29	3.9	4.3	20.3	20.9
2018/11/30	3.9	4.2	20.3	20.7

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 (107)
師(三)級藥師 (203)
臺北榮民總醫院