

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 107年04月

序號	一號冰箱		二號冰箱		三號冰箱		負20度冰箱		負80度冰箱		室溫	
	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
0520-362	0520-293	1504-0305	1213-0010	1215-0006	1213-0007							
0850-0835	0520-292	1504-0339	1405-0193	1330-0064	1405-0194							
2~8°C	2~8°C	2~8°C	負15~負25°C	≤負70°C	15~25°C							
日期	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2018/4/1	4.7	4.9	5.1	5.8	4.4	4.8	-21.1	-20.8	-81.8	-79.9	19.9	20.2
2018/4/2	4.1	4.7	4.2	5.7	4.4	5.3	-20.9	-19.8	-81.6	-80	20.3	21.2
2018/4/3	3.9	4.8	4.1	5.7	4.4	5.4	-20.9	-20.4	-81.7	-79.9	20.1	22.2
2018/4/4	4.5	4.8	4.7	5.7	4.6	5.1	-20.9	-20.8	-81.7	-79.9	21.7	22.1
2018/4/5	4.5	4.8	4.7	5.7	4.6	5.2	-20.9	-20.8	-81.7	-79.9	21.7	21.8
2018/4/6	4.5	4.8	4.7	5.7	4.6	5.1	-21.1	-20.8	-81.8	-79.9	21.3	21.7
2018/4/7	4.5	4.9	4.7	5.7	4.6	5.2	-21.1	-20.8	-81.5	-79.9	20.7	21.3
2018/4/8	4.5	4.8	4.7	5.7	4.6	5.1	-21.1	-20.8	-81.7	-79.9	20.4	20.7
2018/4/9	4.5	5.3	4.2	5.7	4.4	5.4	-21.1	-20.7	-81.7	-79.9	19.9	20.8
2018/4/10	4.4	5.4	4.1	5.7	4.4	5.3	-21.1	-20.4	-81.6	-79.6	19.7	21
2018/4/11	4.4	5.3	4.1	5.7	4.6	5.3	-20.9	-20.2	-81.7	-79.9	19.9	21.3
2018/4/12	4.3	5.3	4.1	5.7	4.7	5.3	-20.9	-20	-81.7	-79.9	20.2	21.4
2018/4/13	4.3	5.2	4.1	5.7	4.6	5.3	-20.8	-19.8	-81.7	-79.9	20.3	21.4
2018/4/14	4.9	5.3	4.8	5.7	4.6	5.2	-19.9	-19.6	-81.7	-79.9	20.3	21.3
2018/4/15	4.9	5.2	4.7	5.7	4.6	5.1	-19.9	-19.7	-81.8	-79.9	19.9	20.6
2018/4/16	4.3	5.1	4.1	5.7	4.5	5.2	-20.2	-19.6	-81.6	-80	19.6	20.8
2018/4/17	4.3	5.2	4.1	5.7	4.5	5.3	-20.9	-18.1	-81.7	-79.9	19.4	20.6
2018/4/18	4.4	5.4	4.2	5.7	4.3	5.1	-20.9	-19.2	-81.8	-79.9	19.2	20.4
2018/4/19	4.5	5.8	4.2	5.6	4.3	4.9	-21.2	-20.7	-81.7	-79.7	19.3	20.4
2018/4/20	4.4	5.3	4.1	5.7	4.3	5.2	-21.2	-20.8	-81.7	-79.9	19.4	20.6
2018/4/21	5.1	5.4	4.7	5.7	4.3	4.9	-21.2	-20.9	-81.8	-79.8	19.4	19.6
2018/4/22	5.2	5.4	4.7	5.6	4.3	4.9	-21.2	-20.9	-81.7	-79.9	19.4	19.5
2018/4/23	4.4	5.4	4.1	5.6	4.3	5.2	-21.2	-20.9	-81.8	-79.9	19.3	20.4
2018/4/24	4.3	5.3	4	5.6	4.3	5.3	-21.2	-20.8	-81.7	-79.9	19.3	20.3
2018/4/25	4.4	5.2	3.9	5.6	4.4	5.2	-21.2	-20.9	-81.8	-79.8	19	20
2018/4/26	4.4	5.2	4	5.6	4.4	5.2	-21.2	-20.6	-81.7	-79.9	18.8	19.9
2018/4/27	4.3	5.3	3.9	5.6	4.4	5.7	-21.2	-20.8	-81.7	-79.9	18.8	19.8
2018/4/28	4.9	5.2	4.6	5.6	4.4	5.1	-21.1	-20.9	-81.7	-79.9	18.8	20.3
2018/4/29	5.1	5.3	4.6	5.6	4.5	5	-21.1	-19.2	-81.7	-79.9	20.3	20.5
2018/4/30	4.4	5.3	4	5.5	4.3	5.8	-21.2	-20.3	-81.7	-79.8	20.4	21.6

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 107
師(三)級藥師 0501
藥學部 溫雅如 107
師(三)級藥師 0501

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 107年04月

	四號冰箱		五號冰箱		室溫2	
序號	1611-0062		1715-0118		1715-0116	
備用	1611-0052		1715-0119		1715-0117	
範圍	2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max
2018/4/1	4.7	5.1	4.7	5.3	22.1	22.7
2018/4/2	4.6	5.1	4.7	5.3	21.8	22.9
2018/4/3	4.6	5.3	4.7	5.3	22.2	23.3
2018/4/4	4.7	5.3	4.7	5.3	22.3	23.1
2018/4/5	4.7	5.3	4.7	5.3	22.1	22.8
2018/4/6	4.7	5.2	4.7	5.3	21.7	22.3
2018/4/7	4.7	5.3	4.7	5.2	21.1	21.7
2018/4/8	4.7	5.2	4.7	5.2	20.7	21.1
2018/4/9	4.7	5.4	4.7	5.3	20.8	22
2018/4/10	4.7	5.3	4.7	5.3	21.6	22.4
2018/4/11	4.7	5.3	4.7	5.3	21.9	23
2018/4/12	4.7	5.2	4.7	5.4	22.3	23.2
2018/4/13	4.7	5.2	4.7	5.4	22.4	23.3
2018/4/14	4.7	5.2	4.8	5.4	22.6	23.2
2018/4/15	4.7	5.1	4.8	5.3	22.2	23
2018/4/16	4.6	5.2	4.7	5.3	21.7	22.2
2018/4/17	4.6	5.1	4.7	5.3	21.6	22.2
2018/4/18	4.5	5.1	4.8	5.3	21.4	22.2
2018/4/19	4.6	5.1	4.7	5.3	21.6	22.3
2018/4/20	4.5	6.6	4.7	5.3	21.7	22.4
2018/4/21	4.5	4.9	4.8	5.3	21.9	22.3
2018/4/22	4.4	4.9	4.8	5.3	21.7	22
2018/4/23	4.4	4.9	4.7	5.6	21.5	22.4
2018/4/24	4.4	5.3	4.8	5.3	21.9	22.4
2018/4/25	4.4	4.9	4.7	5.3	21.6	22.3
2018/4/26	4.4	4.9	4.7	5.3	21.4	22.2
2018/4/27	4.3	4.9	4.7	5.3	21.6	22.2
2018/4/28	4.3	4.9	4.8	5.4	21.8	22.6
2018/4/29	4.3	4.9	4.8	5.4	22.3	22.8
2018/4/30	4.3	4.9	4.7	5.3	22.4	23.4

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 07-9501

藥學部 溫雅如 07-9501