

# 臺北榮民總醫院藥學部

## 臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 106年12月

|            | 四號冰箱      |     | 五號冰箱      |     | 室溫2       |      |
|------------|-----------|-----|-----------|-----|-----------|------|
| 序號         | 1611-0062 |     | 1715-0118 |     | 1714-0116 |      |
| 備用         | 1611-0052 |     | 1715-0119 |     | 1714-0117 |      |
| 範圍         | 2~8℃      |     | 負15~負25℃  |     | 15~25℃    |      |
| 日期         | Min       | Max | Min       | Max | Min       | Max  |
| 2017/12/1  | 4.5       | 5.2 | NA        | NA  | 21.2      | 21.8 |
| 2017/12/2  | 4.5       | 5.2 | NA        | NA  | 21.1      | 21.7 |
| 2017/12/3  | 4.5       | 5.1 | NA        | NA  | 20.7      | 21.2 |
| 2017/12/4  | 4.5       | 5.2 | NA        | NA  | 20.3      | 21.3 |
| 2017/12/5  | 4.4       | 5.2 | NA        | NA  | 20.3      | 21.2 |
| 2017/12/6  | 4.4       | 5.3 | NA        | NA  | 20.3      | 21.4 |
| 2017/12/7  | 4.6       | 5.2 | NA        | NA  | 20.6      | 21.7 |
| 2017/12/8  | 4.5       | 5.2 | NA        | NA  | 20.7      | 21.5 |
| 2017/12/9  | 4.5       | 5   | NA        | NA  | 20.1      | 20.7 |
| 2017/12/11 | 4.5       | 5.2 | NA        | NA  | 19.7      | 20.4 |
| 2017/12/12 | 4.4       | 5.1 | NA        | NA  | 19.2      | 20.1 |
| 2017/12/13 | 4         | 5.5 | NA        | NA  | 19.5      | 20.6 |
| 2017/12/14 | 3.8       | 5.3 | 5.5       | 6.6 | 20.3      | 21.9 |
| 2017/12/15 | 4.4       | 5.3 | 5.5       | 6.1 | 21.4      | 22   |
| 2017/12/16 | 4.4       | 5.2 | 5.3       | 5.7 | 21.3      | 22   |
| 2017/12/17 | 4.5       | 5.2 | 5.3       | 5.6 | 21.2      | 21.9 |
| 2017/12/18 | 4.5       | 5.3 | 5.3       | 5.8 | 20.3      | 21.2 |
| 2017/12/19 | 4.4       | 5.1 | 5.3       | 5.8 | 20.1      | 21.1 |
| 2017/12/20 | 4.3       | 4.8 | 5.3       | 5.6 | 20.3      | 21.4 |
| 2017/12/21 | 4.2       | 5.1 | 5.3       | 5.6 | 20.3      | 21.1 |
| 2017/12/22 | 4.3       | 4.9 | 3.8       | 5.7 | 20.2      | 21.1 |
| 2017/12/23 | 4.3       | 4.7 | 3.7       | 4.7 | 20.8      | 22.3 |
| 2017/12/24 | 4.3       | 4.8 | 3.7       | 4.7 | 21.1      | 21.6 |
| 2017/12/25 | 4.3       | 5.8 | 3.7       | 6.2 | 19.8      | 21.1 |
| 2017/12/26 | 4.4       | 4.9 | 3.8       | 4.7 | 19.7      | 22   |
| 2017/12/27 | 4.3       | 4.9 | 3.7       | 4.7 | 21.5      | 22.6 |
| 2017/12/28 | 4.3       | 4.9 | 3.9       | 4.9 | 21.7      | 22.2 |
| 2017/12/29 | 4.3       | 5.1 | 4.2       | 4.9 | 21.2      | 21.9 |
| 2017/12/30 | 4.3       | 4.8 | 4.2       | 5   | 21.3      | 21.9 |
| 2017/12/31 | 4.3       | 4.8 | 4.1       | 5   | 21.7      | 22.2 |

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

五號冰箱 2017/12/14 設置

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師: 藥學部 邱保祥 (107) 102

藥學部 溫雅如 (107) 102