

臺北榮民總醫院藥學部

臨床試驗藥局一般藥品冷藏/冷凍/室溫溫度管制表 112年 09月

	零號冰箱		四號冰箱		五號冰箱		八號冰箱		九號冰箱		室溫2	
序號	2052-0128		1611-0062		1715-0118		2123-0024		2123-0028		1715-0116	
備用	2052-0129		1611-0052		1715-0119		2123-0025		2123-0029		1715-0117	
範圍	2~8°C		2~8°C		2~8°C		2~8°C		2~8°C		15~25°C	
日期	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
2023/9/1	6.1	7.1	3.9	4.6	4.1	5.2	4.4	5	5	5.4	21.4	22.2
2023/9/2	6.1	6.2	3.9	4.5	4.1	5.2	4.4	4.9	5	5.3	21.3	21.7
2023/9/3	6	6.2	3.9	4.5	4.1	5.2	4.4	4.9	4.9	5.3	21.1	21.3
2023/9/4	4.7	6.1	3.9	4.7	3.9	5.4	4.4	5	4.3	5.6	21.1	21.6
2023/9/5	4.7	5.2	4	4.9	4.2	5.5	4.3	5.8	4.5	5.6	21.4	21.9
2023/9/6	4.3	5.1	4.2	4.8	4.4	6.3	4.9	5.5	5.3	6.1	21.6	21.9
2023/9/7	4.2	4.6	3.9	4.8	4.4	5.9	4.9	5.5	4.8	6.9	21.6	21.8
2023/9/8	4.1	4.6	3.9	4.7	4.2	5.3	4.6	5.4	4.6	5.6	21.4	21.7
2023/9/9	4	4.2	3.9	4.5	4.2	5.3	4.6	5.1	4.6	4.9	21.3	21.6
2023/9/10	4	4.2	3.9	4.5	4.2	5.3	4.6	5.1	4.6	4.9	20.9	21.3
2023/9/11	4	4.4	3.9	4.5	4.3	5.4	4.6	5.3	4.4	4.9	20.8	21.2
2023/9/12	4.1	4.6	3.9	4.6	4.3	5.6	4.8	5.3	4.2	4.9	20.9	21.3
2023/9/13	4.1	4.6	3.9	4.6	4.3	5.3	4.8	5.3	4.2	4.7	21.2	21.4
2023/9/14	4.2	4.7	4	4.7	4.2	7.2	4.6	5.2	4.2	4.7	21.1	21.8
2023/9/15	4.3	4.7	4	4.7	4.4	5.4	4.7	5.3	4.3	4.7	21.1	21.4
2023/9/16	4.3	4.7	4.1	4.7	4.4	5.3	4.9	5.3	4.3	4.6	21.1	21.3
2023/9/17	4.3	4.7	4.1	4.7	4.4	5.3	4.9	5.3	4.3	4.6	20.9	21.1
2023/9/18	4.2	5.4	4.1	5.1	4.4	5.5	4.8	5.5	4.3	4.6	20.7	21.1
2023/9/19	4.9	5.5	4	4.7	4.7	6.3	5.1	5.6	4.3	4.8	20.9	21.3
2023/9/20	3.9	5.5	4.2	4.9	5.9	6.2	5.1	5.6	4.4	4.8	21.2	21.5
2023/9/21	3.9	4.4	4.2	5.1	5.9	6.4	5.2	5.6	4.5	4.9	21.2	21.5
2023/9/22	3.9	4.4	4.2	4.9	5.9	6.3	5.1	5.5	4.1	4.9	21.2	21.6
2023/9/23	3.9	4.5	4.2	4.9	5.9	6.2	5.1	5.5	4.4	4.7	21.3	21.5
2023/9/24	3.9	4.3	4.2	4.7	5.9	6.2	5.1	5.5	4.4	4.7	21.3	21.4
2023/9/25	3.9	4.4	4.1	4.8	5.9	6.4	5.1	5.5	4.3	4.8	21.3	21.9
2023/9/26	3.9	5.6	4.1	4.8	5.9	6.4	5.1	5.6	4.3	4.9	21.3	21.6
2023/9/27	4.7	5.7	4.1	4.9	4.9	6.3	5.2	5.7	4.3	4.9	21.3	21.7
2023/9/28	4.5	4.9	4.2	4.8	4.7	6.6	5.3	5.6	4.3	4.9	21.3	21.7
2023/9/29	4.5	4.8	4.2	4.7	4.7	5.2	5.3	5.6	4.2	4.6	21.1	21.5
2023/9/30	4.5	4.8	4.2	4.7	4.7	5.2	5.3	5.6	4.2	4.7	20.9	21.1

註1: 溫度記錄器型號: ESCORT/ Model No.: EI-IN-D-32-L

註2: 溫度記錄器更換電池或送校正期間取備用紀錄器之資料

承辦藥師

溫度均在正常範圍內

藥學部 邱保祥 112
師(三)級藥師 邱保祥 1002

藥學部 邱予芹 112
師(三)級藥師 邱予芹 1003

總藥師:

藥學部 廖志峰
師(二)級藥師 廖志峰 1003
1910

業管主管:

藥學部 何沁沁 1004
師(一)級藥師 何沁沁 1000

藥學部 張豫立
主任 張豫立